

Springfield ~ Southern State Correctional Facility – Steamline

Replacement.....\$300,000

The buildings at the Southern State Correctional Facility (SSCF) are heated from a central steam boiler system via direct buried distribution piping. The distribution piping has thermal insulation and an outer jacket, which were intended to maintain thermal efficiency and protect the inner distribution pipes from corrosion. Existing distribution pipes have corroded and leaks have occurred. Temporary repairs have been made, but visual inspection of the steam piping indicates complete replacement is required. Funds allocated in FY'14, FY'15, FY'16 and FY'17 have been used to replace approximately 80% of the existing direct buried pipes. The balance of those funds plus the FY'18 appropriation will allow the remaining pipes to be replaced and will complete this project.

Summary Cost Allocation:	Approved Through FY '16	Current Year FY '17	Budget Year FY '18	Budget Year FY '19	Future Requirements			Totals
					FY '20	FY '21	FY '22- FY '27	
Planning & Design, Outside Consultants								
Site Acquisition								
Construction	2,400	200	300					2,900
Fit-Up								
Total Appropriation for Fiscal Year(s)	2,400	200	300					2,900