

Sheffield-Highgate Export Interface

SHEI

Senate Finance Committee
February 23, 2018

vermont electric power company



Flow over SHEI equals total generation minus total load

With due regard to equipment status and negative effects of some generators

- Total load is between 20 MW and 60 MW
 - Average load is 35 MW
- Total generation is 430 MW (all at maximum potential output)
 - Including Highgate 225 MW HVdc converter—largest resource within SHEI
 - Highgate typically runs at maximum capacity almost 24 hours a day

Generation dispatchable by ISO-NE		Generation not dispatchable by ISO-NE	
Utility-scale wind	105 MW	Landfill methane	8 MW
Utility-scale hydro	35 MW	Total solar PV (small & large)	11 MW
Utility-scale thermal (rarely runs)	45 MW	Other standard offer (hydro, farm methane)	3 MW

- Higher SHEI generation from October to May
 - Spring season is more challenging due to higher hydro and lower loads
 - Growing energy efficiency and behind-the-meter/non-dispatchable generation aggravating constraints

SHEI is not a load-serving reliability problem eligible for regional pool transmission funding support

- System concerns can be prevented by backing down generation based on economics and other market rules
- Solutions not eligible for traditional regional cost sharing
- Initial transmission upgrades or non-transmission options could mitigate most *current* SHEI congestion (current generation sources loads)
 - Reactive devices; operational ambient-based ratings; B-20 line upgrade; energy storage
- Robust, long-term solutions that support 90% renewable by 2050 energy vision will be complex and could lead to costly reinforcements and other strategies
 - New transmission lines; new tools (e.g., storage, demand management, strategic electrification); hybrid solutions
- Collective problem that will require multiple stakeholders' engagement

SHEI information posted on VSPC website—public

- July 12, 2017 — SHEI study kickoff and information sharing
<https://www.vermontspc.com/grid-planning/shei-info>
https://www.vermontspc.com/library/document/download/5810/20170712_SHEI_Preso_MtgVersion.pdf
- September 1, 2017 — study update
<https://www.vermontspc.com/library/document/download/5894/SHEI%20Study%20SeptemberUpdate.pdf>
- September 11, 2017 — study update makeup session
<https://www.vermontspc.com/library/document/download/5894/SHEI%20Study%20SeptemberUpdate.pdf>
- October 18, 2017 — final study update
<https://www.vermontspc.com/library/document/download/5894/SHEI%20Study%20SeptemberUpdate.pdf>
- Other information also available at
<https://www.vermontspc.com/grid-planning/shei-info>

Sheffield-Highgate Export Interface study summary

- Hired EIG to study 17 options and 45 combinations, including...
 - Reactive power support, subtransmission and transmission upgrades, and energy storage
- Used VSPC framework to facilitate an open discussion of concerns and solutions
- Key results
 - Logical to address voltage concerns first (B20/B22, SC, AVR)
 - K42 line could be key for relieving thermal concerns
 - Implement ambient-based ratings (static or dynamic)
 - Reconductor as part of asset condition project
- Tensions
 - Short-term and quick solution versus long-term solution with implementation challenges
 - There is not a pre-established mechanism for the cost allocation of economic upgrades
 - Concern over follow on projects benefitting from the solutions
- Stakeholders will select preferred option(s)
- VELCO will provide support as needed

What's next?

- Cost estimates are under development
- Additional analysis underway by affected distribution utilities
- Solution selection by year end
- Continuing public information through VSPC and VSPC website