

All units are ppb		Initial		Re-test		2nd Re-test		Action
School	Fixture	First Draw	Flush	First Draw	Flush	First Draw	Flush	
St. Albans City	AC 209-2 Faucet	26	<1	17	<1	3	<1	Replaced Fixture
Castleton	158 Sink	16	1	<1	1			Replaced Fixture
Castleton	301 Sink	16	2	2	2			Replaced Fixture
Castleton	Kitchenette Standalone Sink	43	2	2	<1			Replaced Fixture
Castleton	111 Sink	23	1	2	<1			Replaced Fixture
Castleton	120 Sink	18	<1	<1	1			Replaced Fixture
Castleton	Kitchenette Double Sink	8	<1	9	4			Replaced Fixture
Richford	Kitchen Pot Filler	25	5	18	<1	1	<1	Replaced Fixture
Richford	Ms West 2nd Grade Sink	17	2	20	2	1	2	Replaced Fixture