

State Action Levels for Lead Testing in Schools

Alabama	20 ppb
Arizona	15 ppb
California	15 ppb
Colorado	15 ppb
District of Columbia	5 ppb
Idaho	20 ppb
Illinois	5 ppb
Indiana	15 ppb
Maine	20 ppb
Maryland	20 ppb
Massachusetts	15 ppb
Michigan	5 ppb (15 pp for some)
Minnesota	No action level specified, shut off tap at 20 ppb
Nevada	20 ppb for 250 ml, 15 ppb for 1 liter
New Hampshire	EPA Standard
New Jersey	15 ppb
New York	15 ppb
North Dakota	15 ppb
Ohio	EPA Action Level or 15 ppb
Oregon	Not specified, but State agency asserts 20 ppb
Pennsylvania	15 ppb
Rhode Island	15 ppb
Utah	15 ppb or 20 ppb
Virginia	Not specified, State agency asserts EPA recommendation
Washington State	20 ppb