

"Douglas, Diane" <Diane.Douglas@greenmountainpower.com>
 To: "jgibson@vermontel.net" <jgibson@vermontel.net>
 Here is the outage information you requested

April 16, 2019 11:09 AM

2 Attachments, 118 KB

Please let me know if you have further question on the information provided.

Diane – Customer Service
 GMP
 1-802-770-3371

Name JONATHAN GIBSON
 Address 2202 KEIFFER RD
 SHREWSBURY, VT 05738
 Account 3410420046-286691
 Account Type
 Meter 6021635

Call Entry Previous Calls Previous Incidents

Previous Incidents

Time Outage	Time Restored	Outage Duration (D H:M)	Incident	Cause	Weather	Dispatcher Remarks	Field Remarks
12/12/2018 11:37 AM	12/12/2018 12:37 PM	0:59	499921	1B TREE Wind - In ROW	<Unknown>	Crew opened up line to remove tree.	
12/3/2018 3:40 PM	12/3/2018 4:14 PM	0:33	499155	1C TREE Snow/Ice - Out ROW	<Unknown>	Crew opened up to remove tree.	
12/2/2018 8:06 AM	12/2/2018 10:37 AM	2:31	498166	2D WEATHER - Snow Load/Wire Slap	<Unknown>	L 4 P 93 Recloser Open	
11/27/2018 10:06 PM	11/29/2018 7:30 PM	1:21:23	496595	1D TREE Snow/Ice - In ROW	<Unknown>	L 4, P 93, crew opened to this recloser so they could energize to here	
11/27/2018 8:40 AM	11/27/2018 4:05 PM	7:24	487463	1C TREE Snow/Ice - Out ROW	<Unknown>	L 4, P 93, recloser open, L 4, Pole 117 cutout open for tap L 49, P 1, tree (off road) L 4, P 118, primary /neutral down	
10/15/2018 9:33 PM	10/16/2018 12:50 AM	3:17	471084	1G TREE - Other - Limb	<Unknown>		
6/13/2018 1:20 PM	6/13/2018 2:58 PM	1:37	444241	1F TREE - Other - In ROW	<Unknown>	L-462 P-24 NP	TREE @ P.11 / OCR OPENED @ P.9
5/5/2018 3:20 AM	5/5/2018 4:30 AM	1:09	437855	1A TREE Wind - Out ROW	<Unknown>	L 4 P 57 Confirmed open L 48, P 1,	
12/14/2017 1:54 PM	12/14/2017 2:20 PM	0:25	410230		<Unknown>	L 6, P.39X -PLANNED OUTAGE TO REMOVE TREE	
10/24/2017 1:17 PM	10/24/2017 3:30 PM	2:13	388775	1F TREE - Other - In ROW	<Unknown>	L 4, P.118 N/P---FD IN ROUTE BRUSH FIRE	

Name JONATHAN GIBSON
 Address 2202 KEIFFER RD
 SHREWSBURY, VT 05738
 Account 3410420046-286691
 Account Type
 Meter 6021635

Call Entry Previous Calls Previous Incidents

Previous Incidents

Time Outage	Time Restored	Outage Duration (D H:M)	Incident	Cause	Weather	Dispatcher Remarks	Field Remarks
8/9/2017 4:30 PM	8/9/2017 6:20 PM	1:50	380937	1B TREE Wind - In ROW	<Unknown>	tree L4 P62- opened ocr at P-57	
5/14/2017 2:44 AM	5/14/2017 4:54 AM	2:10	364281	4X EQUIP - Other	<Unknown>		
5/7/2017 12:26 AM	5/7/2017 9:39 AM	9:12	363674	1A TREE Wind - Out ROW	<Unknown>	SHREWSBURY L- 402 P- X1	
5/5/2017 4:52 PM	5/6/2017 1:40 AM	8:47	362640	1A TREE Wind - Out ROW	<Unknown>	Mt Holly L- 4 P- 34 fuse that protects 408 Mt Holly L- 1022 P-4-2 MT HOLLY L- 2 P- 15 MT HOLLY L- 3 P- 41 LAKE NINEVAH RD.,	
3/8/2017 6:14 AM	3/8/2017 8:23 AM	2:09	352218	1B TREE Wind - In ROW	<Unknown>	TRUCK#225	
1/11/2017 3:47 AM	1/11/2017 6:11 AM	2:23	345051	1B TREE Wind - In ROW	<Unknown>		Wires down at P-113, open at L-4, P-93
12/27/2016 12:40 PM	12/27/2016 1:30 PM	0:50	343983	1A TREE Wind - Out ROW	<Unknown>	L-4 P-66, neutral down at P-90	
12/1/2016 1:58 PM	12/1/2016 2:28 PM	0:30	341966	1B TREE Wind - In ROW	<Unknown>	L-4 P-38 POLE TOP FIRE- TREE AT P38	
11/20/2016 11:40 PM	11/21/2016 3:24 AM	3:44	340466	1D TREE Snow/Ice - In ROW	<Unknown>	L-4 P-93 Crew open for wire down	
11/20/2016 4:32 PM	11/20/2016 6:32 PM	2:00	340187	1C TREE Snow/Ice - Out ROW	<Unknown>		