

State House - 115 State Street

Room Number	Committee	Number of Members	Room Capacity Based on Air Flow	Rooms with VAV Maximum Capacity Allowed with Override
	House Chamber	150	285	
	Senate Chamber	30	171	
	First Floor Lobby, East/West Corridor and Lincoln Corridor		-3	9
1	Senate Judiciary	5	11	19
2	Sergeant at Arms		8	19
3	Senate Transportation	5	8	18
4	Senate Government Operations	5	10	17
5	Senate Appropriations	7	10	23
6	Senate Finance	7	10	23
7	Senate Institutions	5	4	15
8	Senate Natural Resources & Energy	5	8	19
9	Coat Room		3	21
10	Small Hearing Room		8	26
11	Large Hearing Room		40	43
13	President Pro Tempore		7	19
14	Lt. Governor		9	20
16	Lt. Governor Staff		8	20
17	Senate Health & Welfare		9	20
18	Secretary of the Senate		7	16
19	Secretary of the Senate		8	20
20	Senate Cloakroom		8	18
24	Legislative Lounge		49	
26	Senate Agriculture	5	8	
27	Senate Economic Development, Housing, & General Affairs	5	17	
28	Senate Education	6	14	
30	House Judiciary	11	7	
31	House Education	11	5	
32	House Agriculture & Forestry	8	7	
33	House Corrections & Institutions	11	7	
34	House Ways & Means	11	18	
35	House Commerce & Economic Development	11	15	
41	House Energy and Technology	9	8	
42	House Appropriations	11	6	
43	House Transportation	11	15	
44	House General, Housing & Military Affairs	11	8	
45	House Health Care	11	7	
46	House Human Services	11	15	
47	Conference Room	0	8	
48	House Government Operations	11	9	
Ethan Allen	House Natural Resources, Fish, & Wildlife	11	8	

State House - 115 State Street

Room Number	Committee	Number of Members	Room Capacity Based on Air Flow	Rooms with VAV Maximum Capacity Allowed with Override
	Cafeteria (Doors opened, includes entire area)*		68	
	Cafeteria (Doors closed)*		80	
	Cafeteria (Doors closed, Lobby at top of ramp)*		2	
	Cedar Creek Room		-3.68	30
	Speaker of the House		10.00	
	Speaker of the House Vestibule		4.00	
	Speaker of the House Staff		0	
	Hall of Flags		0	
L1	Legislative Council Front Area		20	
L2	Legislative Council Rear Area (Drafters)		17	
L3	Legislative Council Rear Area Office		3	
L4	Legislative Council Front Area Conference Room		3	
M3	Mezzanine		6	
M4	Mezzanine		4	
M5	Mezzanine		4	
M6	Mezzanine		11	
M7	Mezzanine		5	
M8	Mezzanine		4	
M9	Mezzanine		4	
M10	Mezzanine		3	
M11	Mezzanine		3	
M12	Mezzanine		2	
M13	Mezzanine		1	
M14	Mezzanine		3	
M15	Mezzanine		3	

* If cafeteria doors are open, all the air is mixed. If the cafeteria doors are closed, there is limited air flow in the open area south of the glass doors and in the lobby at the top of the ramp.